

GLASGOW FIRE DEPARTMENT
Standard Operating Guideline

GUIDELINE: HOSE LAY PROCEDURES			SECTION: 211
WRITTEN 08/13/90	REVIEWED	REVISED 08/25/2021	Page 93

INTENT

The intent or purpose of hose lay procedures is to ensure that personnel use the hose lays that provide prompt, adequate attack lines and water supply lines.

REFERENCE

1. Personnel shall use hose lays as per Section 135 Training Procedures Minimum Standards.
2. Officers or senior members shall use the hose lays that provide the most effective and efficient attack to suppress the incident.
3. Maximum operating pressure of Relay-supply hose is 185 P.S.I. This would include 3 ½" to 5" hose that is used for relay supply.